



Northbrook

HEALTH & REHABILITATION CENTER

Hello Kevin,

Please find attached, correspondence from MPS Engineering and Consulting Engineering Associates to address the 96 hour fuel supply and also the facility Air Conditioning requirement.

We have also attached a copy of our agreement with our generator maintenance provider (TAW) and attached recent maintenance documentation.

Please feel free to contact me if you have further questions on this matter.

Sincerely,

Steve Webber

Administrator





FIELD REPORT

Date: November 17, 2017
To: Summit Care II, Inc.
From: Scott Roper, PE
Project: Northbrook Health & Rehab
MPS Job #: 217207


RE: Standby Power Assessment as Related to the Governor's Emergency Rule 59AER17-1


Generator – The existing standby generator is an Onan 30KW/37.5KVA diesel with a diesel base tank. The generator is capable of providing 104 Amps at 120/208 Volts 3-phase. The generator has a 100 amp fused disconnect to protect the emergency feeds to the essential electrical system. It is located at the back of the facility in a grassy landscape area. The unit appears to be in serviceable condition and is currently serving the building's emergency electrical system. The existing critical branch transfer switch is rated at 125 Amps. The life safety branch transfer switch is rated for 125 Amps. There are no HVAC units in this facility connected to the essential electrical system.






Electrical Distribution System – The system voltage is 208/120V 3 phase, 4 wire system. The existing 500 KVA pad mount utility transformer is located outside near the main electrical room. The service entrance consists of a main lug 2000 Amp switchboard with six service rated main breakers installed. The distribution equipment is all Square D and appears to be in good condition. There is no main breaker in the switchboard. The peak demand measured in April 2017 is 210KW.





240 Pine Ave. North
Oldsmar, FL 34677

MPS ENGINEERING

 www.mpseng.com

 813.855.2721

AN M.P. SPYCHALA COMPANY

Recommendations – We have surveyed the facility and reviewed available existing plans and have the following recommendations for complying with the emergency rule.

The existing generator is loaded to near max capacity. Due to the size of the existing mechanical equipment a second generator will be required to meet the mandated cooling in the facility. That being the case, there are a few options we can recommend.

Option #1 would be to install a new dedicated optional standby generator with 96 hours of fuel capacity to power the required HVAC equipment that is needed to serve the designated lifeboat areas. The exact size of the generator and how the HVAC equipment would be connected to it would have to be determined through some additional investigative work. The fact that there are currently 6 separate mains in the building (the maximum allowed per code) makes this a more complex scenario. This option would require a new generator with properly sized base tank, a new transfer switch, new distribution panelboard, and revised wiring from the HVAC equipment to the new panelboard. A breaker would need to be placed in one of the existing panels to feed the new transfer switch. A load study may be required to determine if the existing panel can support the additional new load of the rewired HVAC equipment. A mechanical engineer will need to determine what existing or additional units will need to be on emergency power to supply cooling to the lifeboat areas that would be designated to house residents and staff during a prolonged power outage.

Option #2 would be to install a new dedicated optional standby generator with 96 hours of fuel capacity to power the whole building. The new system will consist of a new 275KW generator with properly sized base tank and a new service entrance rated transfer switch.

If you have any questions regarding the information provided above, please call for clarification.

Sincerely,

A handwritten signature in black ink, appearing to read "Scott Roper", written over a horizontal line.

Scott Roper, PE
Principal / Electrical Engineer



8365 Gunn Highway
Tampa, Florida 33626-1608

Phone (813) 448-0225

www.cea-engineers.com

REG: CA3962

NORTHBROOK HEALTH AND REHABILITATION
575 LAMAR AVENUE
BROOKSVILLE, FL 34601

FLORIDA EMERGENCY RULE 59AER17-1
HVAC STUDY

Prepared for:

SUMMIT CARE II, INC.

NOVEMBER 20, 2017

Presented by:



John W. Wells, III, PE
FL PE #49347

TABLE OF CONTENTS

Introduction	Page 3
Field Observations and Evaluation	Page 3 – Page 4
HVAC Load Calculations and Evaluation	Page 4
Existing HVAC Equipment Serving Floors	Page 5
Conclusions	Page 6
Attachment A – Sketch of “Lifeboat” Area	
Attachment B – Calculations	

INTRODUCTION

Consulting Engineering Associates, Inc. (CEA) was retained by Summit Care II, Inc. to calculate the cooling requirements for the existing single story, 120-bed building located at 575 Lamar Avenue, Brooksville, FL 34601, to determine if the area to become the “Lifeboat” is in compliance with Florida Emergency Rule 59AER17-1, and has sufficient cooling capacity to keep the area below 80° F during an emergency event when the cooling system for the “Lifeboat” is on emergency power.

FIELD OBSERVATIONS AND EVALUATION

On October 30, 2017, a field visit was made by Eric O. Vieira, PE, of Consulting Engineering Associates, Inc. to obtain the HVAC equipment information serving the area of the building to become the “Lifeboat” during and after an emergency situation, such as a hurricane. For the area considered for the “Lifeboat”, see **Attachment A**.

Based upon our observations and other generally accepted load factors, the following input values were found and utilized to calculate the HVAC cooling load of the “Lifeboat” area:

Lighting load: 1.5 watts/ft² ⁽¹⁾

Internal Equipment Load: 0.25 watt/ft² (accounts for computers and any other items which may be plugged into emergency receptacles)

People Heat Output: 250 BTU/person sensible; 200 BTU/person latent

Safety Factor: 10%

Wall Height: 8’0”

Ceiling Height: 8'0";

Indoor Temperature: 80° F

Roof U-Factor: 0.05 (R-19 insulation)⁽²⁾

Wall U-Factor: 0.054 (R-19 insulation)

Glazing: Shading Coefficient – 0.7; Double pane; U-factor summer = 0.9; U-factor winter = 0.91

People Load: 120 Residents

Outside Air Based Upon: Existing Record Documents by Leland D. Eisenhower, LTD., dated August 1, 1986.

⁽¹⁾ This is the assumed existing load.

⁽²⁾ Record Documents by Paul G. Sieben, AIA, dated June 9, 1986, indicates the roof is insulated with R-27 batt insulation. However an insulation value of R-19 was utilized in our cooling load calculations to account for the age and non-uniformity of the insulation due to building repairs over the years.

HVAC LOAD CALCULATIONS AND EVALUATION

Utilizing the above input values, we calculated the cooling and heating requirements of the building, see **Attachment B**. In summary, our capacity load calculations indicate that a total 39.42 tons of cooling is required, including the required outside air load, to maintain the maximum indoor temperature of 80° F.

EXISTING HVAC EQUIPMENT SERVING THE "LIFEBOAT"

The "Lifeboat" area identified in the **Attachment A** section of the building is air conditioned by three (3) DX split systems, designated as AHU-1, AHU-2, and AHU-4, which were designed to provide 12,075 CFM of total supply air. The approximate date the air handler was installed is unknown from Manufacturer's nameplate information. The following is a summary of the existing equipment:

AHU / CU-1 (15-tons):

Manufacturer: Carrier
Model Number: 40RUAA16A2A6 / 38AUDA16A0B5A0A0A0
Serial Number: 0714U05214 / 4813U42658
Electrical: 208/3/60

AHU / CU-2 (10-tons):

Manufacturer: Carrier
Model Number: 40RM012 / 38AUZA12A0B5A0A0A0
Serial Number: 2306U11487 / 1513C92834
Electrical: 208/3/60

AHU / CU-4 (15-tons):

Manufacturer: Carrier
Model Number: 40RM - 016 - - B611HC / 38AKS016 - - - 521 - -
Serial Number: 0406X01150 / 3705G50071
Electrical: 208/3/60


CONCLUSIONS

The existing air handlers are of sufficient size to maintain the “Lifeboat” area identified in **Attachment A** to a maximum indoor temperature of 80° F. At the time of use, all doors separating the “Lifeboat” area from adjacent unconditioned areas must be closed to minimize the cooling loss to other areas of the building which do not have their air conditioning systems on the generator.

A test of the existing HVAC equipment should be conducted on AHU-1, AHU-2, and AHU-4 by a certified Test and Balance Agency to verify that the cooling capacity available as it exists today is still in accordance with the Manufacturer’s nameplate rating.

Attachment A

AREA TO BE USED AS "LIFE BOAT"



LIFE BOAT CALCULATIONS:		
REQUIRED:	PROVIDED:	
AREA OF LIFEBOAT (120 RESIDENTS @ 50 SF):	6,000 SF	1,009 SF
	(50 SF/RESIDENT)	(50 SF/RESIDENT)

ATTACHMENT B

**17103 Northbrook Health & Rehab
HVAC Load Analysis**

for

Summit Care II, Inc.



Prepared By:

John W. Wells, III, PE
Consulting Engineering Associates, Inc.
8365 Gunn Highway
Tampa, FL 33626
813-448-0225
Friday, November 17, 2017



General Project Data Input

General Project Information

Project file name: 17103-Load-Calculations.CH8
 Project title: 17103 Northbrook Health & Rehab
 Designed by: Joseph B. Nicotera, EI
 Project date: Tuesday, November 14, 2017
 Weather reference city: TAMPA, FLORIDA, USA
 Client name: Summit Care II, Inc.
 Company name: Consulting Engineering Associates, Inc.
 Company representative: John W. Wells, III, PE
 Company address: 8365 Gunn Highway
 Company city: Tampa, FL 33626
 Company phone: 813-448-0225

Barometric pressure: 29.900 in.Hg.
 Altitude: 19 feet
 Latitude: 28 Degrees
 Mean daily temperature range: 17 Degrees
 Starting & ending time for HVAC load calculations: 1am - 12am
 Number of unique rooms in this project: 14

Building Default Values

Calculations performed: Both heating and cooling loads
 Lighting requirements: 1.50 Watts per square foot
 Equipment requirements: 0.25 Watts per square foot
 People sensible load multiplier: 250 Btuh per person
 People latent load multiplier: 200 Btuh per person
 Room sensible safety factor: 10 %
 Room latent safety factor: 10 %
 Room heating safety factor: 10 %
 People diversity factor: 100 %
 Lighting profile number: 1
 Equipment profile number: 1
 People profile number: 1
 Building default ceiling height: 8.00 feet
 Building default wall height: 8.00 feet

Internal Operating Load Profiles (C = 100)

	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
1	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C
2	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C
3	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C
4	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C
5	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C
6	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C
7	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C
8	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C
9	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C
10	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C



General Project Data Input (cont'd)

Building-Level Design Conditions

Design Month	Outdoor Dry Bulb	Outdoor Wet Bulb	Indoor Rel.Hum	Indoor Dry Bulb	Grains Diff	In/Outdoor Correction
August	91	80	50%	80	61.06	-5
June	91	80	50%	80	61.06	-5
July	91	80	50%	80	61.06	-5
September	91	80	50%	80	61.06	-5
January	79	67	50%	80	3.39	-17
December	82	69	50%	80	8.97	-14
Winter	34			70		

Master Roofs

Roof No.	ASHRAE Roof#	Roof U-Fac	Dark Color	Susp. Ceil
1	1	0.050	Yes	Yes

Roof #1 Description: Pitched roof, asphalt shingles with 5/16" plywood, suspended ceiling below with R-19 insulation

Master Walls

Wall No.	ASHRAE Group	Wall U-Fac	Wall Color
1	C	0.054	M

Wall #1 Description: Frame wall, hollow metal framing, stucco exterior, interior finish, R-19 batt insulation

Master Partitions

Partition No.	Partition U-Factor	Cool T-D	Heat T-D
1	0.360	10	20

Partition #1 Description: Frame partition, hollow metal framing, siding exterior, no insulation or finish

Master Glass

Glass No.	Summer U-Factor	Winter U-Factor	Glass Shd.Coef.	Interior Shading	Interior Shd.Coef
1	0.900	0.910	0.700	2	0.000

Glass #1 Description: 1/4" single-pane window, low e, heat-absorbing pattern, insulated metal frame, no int shading

Master Shading Devices

Shade No.	Dist Horiz Projects	Dist Beyond Right W.Edge	Dist Beyond Left W.Edge	Dist Overh Above Wind	Dist Right Fin Proj	Dist R-Fin Beyond W.Edge	Ht Of Right Fin	Dist Left Fin Proj	Dist L-Fin Beyond W.Edge	Ht Of Left Fin
1	9.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00



Air Handler #1 - Existing AHU-1 - Summary Loads

Rm No	Description Room Peak Time	Area People Volume	Htg.Loss Htg.CFM CFM/Sqft	Sen.Gain Clg.CFM CFM/Sqft	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.CFM Act.CFM	Clg.O.A. Req.CFM Act.CFM
1	Area 1 2pm June	863 23 6,904	9,546 524 0.61	22,014 774 0.90	5,060 0 0	Direct 332 524	Direct 332 320
7	Corridor 5pm August	1,635 13 13,080	12,229 671 0.41	30,963 1,975 1.21	2,860 0 0	Direct 629 671	Direct 629 815
8	Physical Therapy 2pm December	518 10 4,144	2,659 146 0.28	10,678 375 0.72	2,200 0 0	Direct 199 146	Direct 199 155
9	DON (NIC) 2pm December	145 0 1,160	1,289 71 0.49	4,097 300 2.07	0 0 0	Direct 56 71	Direct 56 124
10	Central Bathing (NIC) 3pm June	404 0 3,232	3,028 166 0.41	5,014 325 0.80	0 0 0	Direct 155 166	Direct 155 134
11	Washing (NIC) 3pm June	1,504 0 12,032	6,791 373 0.25	16,603 975 0.65	0 0 0	Direct 579 373	Direct 579 402
	Room Peak Totals:	5,069	35,541	89,368	10,120		
	Total Rooms: 6	46	1,950	4,725	0	1,950	1,950
	Unique Rooms: 6	40,552	0.38	0.93	0	1,950	1,950



Air Handler #1 - Existing AHU-1 - Total Load Summary

Air Handler Description: Existing AHU-1 Constant Volume - Proportion
 Supply Air Fan: Draw-Thru with program estimated horsepower of 0.56 HP
 Fan Input: 80% motor and fan efficiency with 0.6 in. water across the fan
 Sensible Heat Ratio: 0.92 --- This system occurs 1 time(s) in the building. ---

Air System Peak Time: 3pm in September.
 Outdoor Conditions: Clg: 91° DB, 80° WB, 137.58 grains, Htg: 34° DB
 Indoor Conditions: Clg: 80° DB, 50% RH, Htg: 70° DB

Summer: Ventilation controls outside air, ---- Winter: Ventilation controls outside air.

Room Space sensible loss:	35,541 Btuh	
Infiltration sensible loss:	0 Btuh	0 CFM
Outside Air sensible loss:	75,764 Btuh	1,950 CFM
Supply Duct sensible loss:	0 Btuh	
Return Duct sensible loss:	0 Btuh	
Return Plenum sensible loss:	0 Btuh	
Total System sensible loss:		111,305 Btuh

Heating Supply Air: $35,541 / (.999 \times 1.08 \times 17) =$	1,950 CFM
Winter Vent Outside Air (100.0% of supply) =	1,950 CFM

Room space sensible gain:	84,802 Btuh	
Infiltration sensible gain:	0 Btuh	
Draw-thru fan sensible gain:	1,414 Btuh	
Supply duct sensible gain:	0 Btuh	
Reserve sensible gain:	22,848 Btuh	
Total sensible gain on supply side of coil:		109,065 Btuh

Cooling Supply Air: $109,065 / (.999 \times 1.1 \times 21) =$	4,725 CFM
Summer Vent Outside Air (41.3% of supply) =	1,950 CFM

Return duct sensible gain:	0 Btuh	
Return plenum sensible gain:	0 Btuh	
Outside air sensible gain:	23,579 Btuh	1,950 CFM
Blow-thru fan sensible gain:	0 Btuh	
Total sensible gain on return side of coil:		23,579 Btuh
Total sensible gain on air handling system:		132,643 Btuh

Room space latent gain:	10,120 Btuh	
Infiltration latent gain:	0 Btuh	
Outside air latent gain:	80,925 Btuh	
Total latent gain on air handling system:		91,045 Btuh
Total system sensible and latent gain:		223,688 Btuh

Check Figures

Total Air Handler Supply Air (based on a 21° TD):	4,725 CFM
Total Air Handler Vent. Air (41.27% of Supply):	1,950 CFM
Total Conditioned Air Space:	5,069 Sq.ft
Supply Air Per Unit Area:	0.9321 CFM/Sq.ft
Area Per Cooling Capacity:	271.9 Sq.ft/Ton
Cooling Capacity Per Area:	0.0037 Tons/Sq.ft
Heating Capacity Per Area:	21.96 Btuh/Sq.ft
Total Heating Required With Outside Air:	111,305 Btuh
Total Cooling Required With Outside Air:	18.64 Tons



Air Handler #2 - Existing AHU-2 - Summary Loads

Rm No	Description Room Peak Time	Area People Volume	Htg.Loss Htg.CFM CFM/Sqft	Sen.Gain Clg.CFM CFM/Sqft	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.CFM Act.CFM	Clg.O.A. Req.CFM Act.CFM
2	Dining 11am August	1,368 24 10,944	9,558 354 0.26	30,150 1,800 1.32	5,280 0 0	Direct 251 140	Direct 251 269
3	Dining Corridor 5pm August	430 5 3,440	6,961 258 0.60	15,259 700 1.63	1,100 0 0	Direct 79 102	Direct 79 104
12	Visitor Lounge (NIC) 6pm September	929 0 7,432	17,579 652 0.70	32,310 850 0.91	0 0 0	Direct 170 258	Direct 170 127
	Room Peak Totals:	2,727	34,097	77,718	6,380		
	Total Rooms: 3	29	1,264	3,350	0	500	500
	Unique Rooms: 3	21,816	0.46	1.23	0	500	500



Air Handler #2 - Existing AHU-2 - Total Load Summary

Air Handler Description: Existing AHU-2 Constant Volume - Proportion
 Supply Air Fan: Draw-Thru with program estimated horsepower of 0.40 HP
 Fan Input: 80% motor and fan efficiency with 0.6 in. water across the fan
 Sensible Heat Ratio: 0.92 --- This system occurs 1 time(s) in the building. ---
 Air System Peak Time: 6pm in September.
 Outdoor Conditions: Clg: 87° DB, 79° WB, 137.66 grains, Htg: 34° DB
 Indoor Conditions: Clg: 80° DB, 50% RH, Htg: 70° DB

Summer: Ventilation controls outside air, ---- Winter: Ventilation controls outside air.

Room Space sensible loss:	34,097 Btuh	
Infiltration sensible loss:	0 Btuh	0 CFM
Outside Air sensible loss:	19,427 Btuh	500 CFM
Supply Duct sensible loss:	0 Btuh	
Return Duct sensible loss:	0 Btuh	
Return Plenum sensible loss:	0 Btuh	
Total System sensible loss:		53,524 Btuh

Heating Supply Air: $34,097 / (.999 \times 1.08 \times 25) =$	1,264 CFM
Winter Vent Outside Air (39.6% of supply) =	500 CFM

Room space sensible gain:	72,756 Btuh	
Infiltration sensible gain:	0 Btuh	
Draw-thru fan sensible gain:	1,002 Btuh	
Supply duct sensible gain:	0 Btuh	
Reserve sensible gain:	3,561 Btuh	
Total sensible gain on supply side of coil:		77,319 Btuh

Cooling Supply Air: $77,319 / (.999 \times 1.1 \times 21) =$	3,349 CFM
Summer Vent Outside Air (14.9% of supply) =	500 CFM

Return duct sensible gain:	0 Btuh	
Return plenum sensible gain:	0 Btuh	
Outside air sensible gain:	3,847 Btuh	500 CFM
Blow-thru fan sensible gain:	0 Btuh	
Total sensible gain on return side of coil:		3,847 Btuh
Total sensible gain on air handling system:		81,167 Btuh

Room space latent gain:	6,380 Btuh	
Infiltration latent gain:	0 Btuh	
Outside air latent gain:	20,674 Btuh	
Total latent gain on air handling system:		27,054 Btuh
Total system sensible and latent gain:		108,221 Btuh

Check Figures

Total Air Handler Supply Air (based on a 21° TD):	3,349 CFM
Total Air Handler Vent. Air (14.93% of Supply):	500 CFM
Total Conditioned Air Space:	2,727 Sq.ft
Supply Air Per Unit Area:	1.2282 CFM/Sq.ft
Area Per Cooling Capacity:	302.4 Sq.ft/Ton
Cooling Capacity Per Area:	0.0033 Tons/Sq.ft
Heating Capacity Per Area:	19.63 Btuh/Sq.ft
Total Heating Required With Outside Air:	53,524 Btuh
Total Cooling Required With Outside Air:	9.02 Tons



Air Handler #3 - Existing AHU-4 - Summary Loads

Rm No	Description Room Peak Time	Area People Volume	Htg Loss Htg CFM CFM/Sqft	Sen Gain Clg CFM CFM/Sqft	Lat Gain S.Exh W.Exh	Htg O.A. Req CFM Act CFM	Clg O.A. Req CFM Act CFM
4	Corridor 3pm June	1,062	6,992	16,007	1,760	Direct	Direct
		8	259	1,550	0	196	196
		8,496	0.24	1.46	0	183	281
5	Multi-Purpose 3pm June	426	1,442	8,503	3,080	Direct	Direct
		14	53	258	0	79	79
		3,408	0.13	0.61	0	38	47
6	Lounge 2pm September	1,014	13,598	30,194	5,060	Direct	Direct
		23	504	916	0	187	187
		8,112	0.50	0.90	0	356	166
13	Central Bathing (NIC) 3pm June	568	2,202	6,079	0	Direct	Direct
		0	82	725	0	105	105
		4,544	0.14	1.28	0	58	131
14	Central Bathing (NIC) 3pm June	864	3,450	9,096	0	Direct	Direct
		0	128	550	0	159	159
		6,912	0.15	0.64	0	90	100
Room Peak Totals:		3,934	27,684	69,879	9,900		
Total Rooms: 5		45	1,026	3,999	0	725	725
Unique Rooms: 5		31,472	0.26	1.02	0	725	725



Air Handler #3 - Existing AHU-4 - Total Load Summary

Air Handler Description: Existing AHU-4 Constant Volume - Proportion
 Supply Air Fan: Draw-Thru with program estimated horsepower of 0.63 HP
 Fan Input: 80% motor and fan efficiency with 0.8 in. water across the fan
 Sensible Heat Ratio: 0.90 --- This system occurs 1 time(s) in the building. ---
 Air System Peak Time: 3pm in September.
 Outdoor Conditions: Clg: 91° DB, 80° WB, 137.58 grains, Htg: 34° DB
 Indoor Conditions: Clg: 80° DB, 50% RH, Htg: 70° DB

Summer: Ventilation controls outside air, ---- Winter: Ventilation controls outside air.

Room Space sensible loss:	27,684 Btuh	
Infiltration sensible loss:	0 Btuh	0 CFM
Outside Air sensible loss:	28,169 Btuh	725 CFM
Supply Duct sensible loss:	0 Btuh	
Return Duct sensible loss:	0 Btuh	
Return Plenum sensible loss:	0 Btuh	
Total System sensible loss:		55,852 Btuh

Heating Supply Air: $27,684 / (.999 \times 1.08 \times 25) =$	1,026 CFM
Winter Vent Outside Air (70.7% of supply) =	725 CFM

Room space sensible gain:	68,883 Btuh	
Infiltration sensible gain:	0 Btuh	
Draw-thru fan sensible gain:	1,596 Btuh	
Supply duct sensible gain:	0 Btuh	
Reserve sensible gain:	21,843 Btuh	
Total sensible gain on supply side of coil:		92,323 Btuh

Cooling Supply Air: $92,323 / (.999 \times 1.1 \times 21) =$	3,999 CFM
Summer Vent Outside Air (18.1% of supply) =	725 CFM

Return duct sensible gain:	0 Btuh	
Return plenum sensible gain:	0 Btuh	
Outside air sensible gain:	8,766 Btuh	725 CFM
Blow-thru fan sensible gain:	0 Btuh	
Total sensible gain on return side of coil:		8,766 Btuh
Total sensible gain on air handling system:		101,089 Btuh

Room space latent gain:	9,900 Btuh	
Infiltration latent gain:	0 Btuh	
Outside air latent gain:	30,087 Btuh	
Total latent gain on air handling system:		39,987 Btuh
Total system sensible and latent gain:		141,077 Btuh

Check Figures

Total Air Handler Supply Air (based on a 21° TD):	3,999 CFM
Total Air Handler Vent. Air (18.13% of Supply):	725 CFM
Total Conditioned Air Space:	3,934 Sq.ft
Supply Air Per Unit Area:	1.0166 CFM/Sq.ft
Area Per Cooling Capacity:	334.6 Sq.ft/Ton
Cooling Capacity Per Area:	0.0030 Tons/Sq.ft
Heating Capacity Per Area:	14.20 Btuh/Sq.ft
Total Heating Required With Outside Air:	55,852 Btuh
Total Cooling Required With Outside Air:	11.76 Tons



PREVENTIVE MAINTENANCE AGREEMENT
Engine and Generator Systems

March 9, 2012

Heartland of Brooksville ("Customer"), of 575 Lamar Avenue, Brooksville, Florida, 34601 and TAMPA ARMATURE WORKS, INC., ("Contractor or TAW") of, 6312 78th Street, Riverview Florida, 33578, in consideration of the promises made in this Agreement and intending to be legally bound, agree as follows:

RECITALS

Customer owns a generator system, together with associated equipment (herein "System"), for use by Customer in providing emergency and other sources of electrical power to a facility or facilities owned or operated by Customer. Contractor is engaged in the service and maintenance of systems like the System owned or operated by Customer and has been requested to provide maintenance and/or testing to the System pursuant to the terms and conditions of this Agreement (the "Services").

MAINTENANCE SERVICES

1. Contractor shall maintain and service the System, consisting of the equipment on Exhibit "A" attached to this Agreement and incorporated herein by reference (the "Equipment"), in accordance with schedule of Services described on Exhibit "A". Contractor shall provide scheduled preventive maintenance, with the schedule to be based on the specific needs of the Equipment as determined by Contractor. In addition, Contractor may provide other remedial maintenance and/or testing at Customer's request, as and when needed. Service maintenance and/or testing may include, without limitation, lubrication, adjustments, testing, and replacement of parts and components deemed necessary by Contractor. Scheduled Maintenance shall include those items of service and/or testing described on Exhibit "A" attached hereto, to be performed by Contractor at the intervals specified hereon. Other maintenance and/or testing requested by Customer and not described on Exhibit "A" shall include those items of service requested by Customer and agreed upon by Contractor.

EXCLUSIONS

.. Unless otherwise agreed by Contractor in writing, the service and maintenance performed pursuant to this Agreement shall not include any of the following:

- (a) Electrical work external to the Equipment
- (b) Furnishing of supplies or accessories.
- (c) Painting or refinishing the Equipment or Furnishing the material therefor.
- (d) Making specification changes to the Equipment.
- (e) Performing services connected with relocation of the Equipment.
- (f) Repairing damage resulting from, or furnishing parts required as a result of causes other than ordinary wear and tear including, without limitation: neglect; misuse, including faulty repair or maintenance by persons other than the Contractor; accidents; failure of electrical power, air conditioning, humidity control or events outside the reasonable control of Contractor, such as, but not limited to, Acts of God.
- (g) Adding, removing, servicing, or maintaining accessories, attachments, or other devices not furnished by Contractor, unless specifically scheduled on Exhibit "A".
- (h) Others: _____

PARTS

3. Contractor shall furnish parts as necessary at Contractor's then current scheduled price or on an exchange basis, regardless of when installed and such parts shall be either new or equivalent to new in performance when used in the Equipment.

CHARGES

- 4. (A) Charges for the preventive maintenance described on Exhibit "A" are described herein.
- (b) Charges for on-call, unscheduled service, or for Services otherwise requested by Customer, shall be at the rates then published and agreed upon by Contractor, in writing.

PAYMENT OF CHARGES

5. Customer agrees to pay Contractor immediately upon completion for the scheduled maintenance described on Exhibit "A". Customer otherwise agrees to pay Contractor for all on-call, unscheduled or otherwise Customer requested maintenance charges immediately on completion unless otherwise agreed by Contractor in writing. If Contractor elects to accept payment from Customer other than on completion for the Services provided pursuant to this Agreement, Customer shall promptly comply with terms of payment granted by Contractor. Any payment due, shall entitle Contractor to seek, in addition to the principal amount owed, interest at eighteen percent (18%) per year or maximum rate allowable by Florida law.

TERM

6. This Agreement shall be effective from the date of its execution by Contractor and Customer and shall remain in force unless terminated, in writing, by either party giving the other thirty (30) days written notice as provided herein. However, the giving of notice of termination shall not relieve or eliminate the obligations of the Contractor and/or Customer occurring before the termination date, unless otherwise agreed by the parties hereto in writing.

WARRANTY; LIMITATION

7. (a) Contractor warrants that under normal conditions of use and operation, the Services furnished pursuant to this Agreement shall be free from defects in workmanship and that the parts furnished pursuant to this Agreement shall be free from defects in workmanship and material.
- (b) Contractor's obligation under this warranty is limited to the repair or replacement, at its option, of any part that, within ninety (90) days after installation and acceptance, is established by Contractor not to be in conformity with the Equipment manufacturer's published specifications. Contractor further warrants that its Services rendered pursuant to this Agreement shall be free of defects in workmanship for ninety (90) days after performance of Services, but Contractor's obligation shall be limited to correction of the defective workmanship.
- (c) The foregoing warranty and conditions shall apply only to any repaired or replaced product, part, or component supplied by Contractor, together with the workmanship as provided herein.
- (d) THIS WARRANTY IS EXCLUSIVE AND IN LIEU OF ALL OTHER WARRANTIES, EXPRESS OR IMPLIED, INCLUDING ANY IMPLIED WARRANTY OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE
- (e) Customer agrees that the sole remedies for the breach of any warranties contained in this Agreement are those expressly stated in this provision. Customer further agrees that in no event shall Contractor's liability to Customer for damages of any nature exceed the total charges paid or payable for either (1) the total charges paid or payable for all Services during one (1) year under this Agreement if the liability arises from the provision of such Services; or (2) the purchase price of the parts if the liability results from the provision of such parts.

ACCESS TO EQUIPMENT; PERFORMANCE OF SERVICES; CUSTOMER OBLIGATIONS

8. (a) Contractor's maintenance personnel shall have free access to the System and the Equipment for the purpose of providing maintenance service.
- (b) During the Services provided pursuant to this Agreement as to the System, whether an interruption in electrical services is contemplated by Customer or Contractor or not, as a matter of allocating between Customer and Contractor the risks associated with an interruption in electrical services and/or taking the System off line, Customer agrees to use its best efforts to fully and completely secure all or any part of any facility in which the System is located, as the case may be, for any and all safety issues that an electrical service interruption might give rise to, including but not limited to, injury to building occupants, customers, invitees, or any third party and/or property damage, or work interruption, arising out of any event of maintenance or testing performed by Contractor as to the System. Customer agrees with Contractor that securing of the premises in order for Contractor to perform its Services is a material and critical element of this Agreement and, prior to the performance of any maintenance and/or testing Services under this Agreement, Customer will receive and execute with Contractor a written Notification and Acknowledgement of Inspection and Warning ("Notification") related to the Services provided herein. The Notification shall include Contractor's estimate as to when interruption of electrical services may occur during the performance of its obligations under this Agreement. Customer further agrees that Contractor shall have no liability to Customer or any third party for any estimate given in connection with potential interruptions in electrical services during the performance of Contractor's obligations herein, it being acknowledged by Customer that Contractor's Services are often affected by acts of third parties and/or components or elements of the System that do not allow for more specific and accurate estimates as to when an electrical service interruption may occur.

DELAYS

9. Contractor shall not be liable for any delays in performance directly or indirectly resulting from acts of Customer, its agents, employees, or subcontractors, or causes beyond the reasonable control of Contractor. "Causes beyond the reasonable control of Contractor" include, but are not limited to:

- | | |
|---|--|
| (a) Acts of God | (h) Strikes, civil commotions, or revolutions |
| (b) Acts of a public enemy | (i) Freight embargos |
| (c) Acts of the United States or the District of Columbia, or any State or Territory of the United States, or any of their political subdivision. | (j) Unusually severe weather conditions |
| (d) Fire | (k) Default of Contractor's subcontractors or suppliers |
| (e) Flood | (l) Normal wear and tear |
| (f) Epidemics | (m) Overloads |
| third parties | (n) Improper operation and/or abuse of the System by Customer or other |
| (g) Quarantine restrictions | (o) Accidents beyond the reasonable control of Contractor. |

CONSEQUENTIAL DAMAGES

10. CUSTOMER AGREES THAT CONTRACTOR SHALL NOT BE LIABLE FOR ANY SPECIAL, INCIDENTAL, OR CONSEQUENTIAL DAMAGES OR FOR THE LOSS OF PROFITS, REVENUES, OR ANY OTHER LOSSES ARISING OUT OF ANY DEFAULT UNDER THIS AGREEMENT, EVEN IF CONTRACTOR SHALL HAVE BEEN ADVISED OF THE POSSIBILITY OF SUCH POTENTIAL LOSS OR DAMAGE.

IDEMNIFICATION OF CONTRACTOR

11. Customer agrees to defend, hold harmless, and indemnify Contractor, its officers, directors, employees and agents for any and all losses, damages, and liabilities, legal or non-legal, arising out of any interruption in electrical services or as to any other incident or event as to the System which is not caused by the willful misconduct or gross negligence of Contractor. Customer further agrees with Contractor that this Agreement of indemnification shall include, without limitation, any attorney's fees, costs or other legal or non-legal expenses of any description incurred by Contractor.

TERMINATION

12. Contractor shall have the right to terminate this Agreement in the event any one of the following instances of default occurs and is not remedied within seven (7) days after receipt of a written notice thereof:
- (a) Failure of Customer to pay or make financial arrangements satisfactory to Contractor for the Services described herein;
- (b) Customer's failure to perform or observe any of the terms and conditions under this Agreement, including, without limitation, timely payment of any sums due Contractor;
- (c) Any assignment of Customer's business or assets for the benefit of creditors;
- (d) The filing of a petition in bankruptcy by or against Customer;
- (e) The appointment of a receiver, trustee in bankruptcy, or similar officer to take charge of all or part of Customer's property;
- (f) Others: _____

MISCELLANEOUS

13. In addition to the other terms and conditions of this Agreement, Customer and Contractor further agree that the following shall also govern this Agreement:

- (a) Waiver. No waiver of any of the terms or conditions of this Agreement shall be binding or effective for any purpose unless expressed in writing and executed by the party giving the same.
- (b) Governing Law; Constitution. This Agreement is being delivered and performed in the State of Florida and shall be construed in accordance with, and governed by, the laws of the State of Florida. Venue of any action related to this Agreement shall be placed in the courts of Polk or Hillsborough County, Florida, exclusively. This Agreement, together with any other documents executed in conjunction with or pursuant to this Agreement shall not be construed against either Customer or Contractor, regardless of which party drafted the Agreement, it being intended this Agreement is the product of informed negotiations between both parties with full knowledge of the meaning of the terms and conditions hereto.
- (c) Enforcement in connection with any action out of this Agreement, or in any way relating to the transactions contemplated hereby, the prevailing party in such action shall be entitled to recover from the non-prevailing party, all court costs and expenses of litigation, including attorney's fees, court costs, costs of investigation, accounting and other costs reasonably related to the litigation, including, but without limitation, all attorney's fees and costs subsequent to entry of any judgment on behalf of the prevailing party, on appeal, in connection with any bankruptcy proceedings, or in any alternative dispute resolution proceedings. **THE PARTIES TO THIS AGREEMENT HEREBY WAIVE, WITHOUT EXCEPTION, ANY RIGHT TO JURY TRIAL RELATED TO ANY ISSUE OR MATTER ARISING OUT OF OR IN CONNECTION WITH THIS AGREEMENT.**
- (d) Successors and Assigns. All of the terms and conditions of this Agreement, and the rights and obligations of the parties hereunder, shall be binding upon and shall inure to the benefit of the respective heirs, personal representatives, successors and assigns of the parties hereto.
- (e) Entire Agreement. This Agreement, any Agreements referenced herein and exhibits attached hereto constitute the entire Agreement and understanding of the parties with respect to the transactions contemplated hereby as an exclusive statement, and incorporate and supersede all prior and contemporaneous negotiations, agreements and understandings related to the subject matter hereof. This Agreement, referenced Agreements, and exhibits may not be amended, terminated or otherwise modified, except by a written instrument executed by all of the parties to be bound thereby.
- (f) Notice. Subject to notice of change of address, in the manner provided in this Paragraph, any notice, request, instruction, or other document to be given under this Agreement by any party to any other party shall be in writing, signed by or on behalf of the party giving notice, and shall be deemed to have been given on the earlier to occur of:
 - 1. the date of actual delivery; or
 - 2. five (5) days after the date on which such notice is mailed by United States Mail, postage prepaid to each party at the addresses listed below; or
 - 3. the date of electronic facsimile transmission that is verified by the issuance of a successful facsimile transmission report at the facsimile telephone number for the receiving party, which is currently on file with the sending party; or the business day following the day on which such notice is sent by any next day or overnight delivery service to each party at the address listed below.
- (g) All scheduled PM appointments canceled by customer when technician arrives at site will be subject to a cancellation fee. A three (3) hour minimum Service call charge will be charged to customer.

If to the customer: Heartland of Brooksville
 575 Lamar Avenue
 Brooksville Florida 34601

 Phone: 352-799-2226
 Fax: 352-799-3368

If to the Contractor: Tampa Armature Works, Inc.
 Attn: Tom Phillips
 6312 78th Street
 Riverview, FL 33569
 Phone: 800-456-9449
 Fax: 813-217-8074

With copy to: James A. Turner III
 Tampa Armature Works, Inc.
 6312 78th Street
 Riverview, FL 33578

Neither party shall hold the other in default hereunder without first giving seven (7) days written notice of default and specifying the action required to cure the default.

Please print and sign both areas of the contract including the Exhibit page.

CUSTOMER: Tabby McCleary
Signed By: *Tabby McCleary* Title: *Administrative*
Print Name: TABBY MCCLEARY Date: 3/28/2012

CONTRACTOR
Tampa Armature Works, Inc.

By: John St. Louis

As its: Account Representative

**PROPOSAL EXHIBIT A
PREVENTATIVE MAINTENANCE PROPOSAL
ENGINE-GENERATOR SYSTEMS
SEMI-ANNUAL INSPECTION**

Proposal #

March 9, 2012

Upon acceptance of this proposal TAW will perform the services listed below, TAW will inspect during business hours at least 2 times each year while this agreement remains in effect. These inspections will include:

- | | |
|---|--|
| <input checked="" type="checkbox"/> Lube, oil and filter change (Once/year) | <input checked="" type="checkbox"/> Check alternator charge rate |
| <input checked="" type="checkbox"/> Fuel filter change (Once/year) | <input checked="" type="checkbox"/> Confirm engine and generator gauge operation |
| <input checked="" type="checkbox"/> Check air cleaner (Once/year) | <input checked="" type="checkbox"/> Confirm generator controller operation |
| <input checked="" type="checkbox"/> Check coolant level | <input checked="" type="checkbox"/> Check unit output voltage and adjust as necessary |
| <input checked="" type="checkbox"/> Test anti-freeze and adjust | <input checked="" type="checkbox"/> Check Fuel Tank Level |
| <input checked="" type="checkbox"/> Inspect belts condition | <input checked="" type="checkbox"/> Inspect fuel line and electrical connections |
| <input checked="" type="checkbox"/> Check engine heater operation | <input type="checkbox"/> Annual Fuel Analysis (Optional \$95.00) |
| <input checked="" type="checkbox"/> Inspect air intakes and outlets | <input type="checkbox"/> Annual Oil Analysis (Optional \$40.00) |
| <input checked="" type="checkbox"/> Check transfer tank operation | <input type="checkbox"/> Annual Coolant Analysis (Optional \$55.00) |
| <input checked="" type="checkbox"/> Drain exhaust line | <input type="checkbox"/> Annual Resistive Load Bank Test 2 Hour (Optional) |
| <input checked="" type="checkbox"/> Inspect silencer | <input type="checkbox"/> Check Interstitial/leak alarm in double wall diesel fuel tank |
| <input checked="" type="checkbox"/> Check battery charger operation and charging rate | <input type="checkbox"/> (Optional \$75.00 Once/Year) |
| <input checked="" type="checkbox"/> Check battery electrolyte levels and specific gravity | <input type="checkbox"/> Resistive Load Bank Test 4 Hour (Optional Every 3 rd Year) |
| <input checked="" type="checkbox"/> Emergency system operation without load transfer | |
| <input checked="" type="checkbox"/> *Emergency system operation with load transfer (If Allowed) | |
| <input checked="" type="checkbox"/> Frequency check/governor adjustment | |
| <input checked="" type="checkbox"/> **Confirm transfer switch and accessory operation | |

**** Where Applicable and With Customer Written Permission.**

Contract price is based on normal business hours (8:00 AM to 4:30 PM Monday through Friday)

Manufacturer / KW	Model	Serial Number	Location	Major	1 Semi Minor(s) @	Sub-Total
Onan	30DL6	K860856086	575 Lamar Ave	\$418.75	\$206.25	\$625.00
Onan	LT	TBD	Same as Above	\$0.00	\$0.00	Included
SUB-TOTAL						\$625.00

2 Hour Load Bank Testing: (Optional) \$0.00 4 Hour Load Bank Testing (Optional) \$0.00

Sub-Total: \$625.00

State Sales Tax: \$37.50

County Sales Tax: \$6.25

Total: \$668.75

All Sales Tax is due on all work unless a valid tax-exempt certificate is supplied.

This proposal is open for acceptance for 30 days.

Terms & Conditions: TAW Preventative Maintenance Agreement & Notification incorporated herein.

Proposal Acceptance

[Signature] _____ Date 3/28/12

Tampa Armature Works, Inc. _____ Date

****CONTRACT IS NON-BINDING IF NOT SIGNED BY BOTH THE CUSTOMER AND THE CONTRACTOR****



TAW Power Systems, Inc.

6312 78TH STREET
RIVERVIEW, FL 33578
Tel: 800-456-9449
Fax: (813) 217-8462

TAW Service Order

BILL TO: 201551 Net 30 days
NORTHBROOK HEALTH & REHAB CENTER
575 LAMAR AVE
BROOKSVILLE, FL 34601

SHIP TO: 201551
NORTHBROOK HEALTH & REHAB
575 LAMAR AVE
BROOKSVILLE, FL 34601

(352)799-2226

Lat.: 28.550488
Lon.: -82.393650


c24 BATT (1)


Service ID.....: SO26450887 Major: No
Agreement.....: Tech: CRAWFORD VINCENT J Caller name: DEAN
Service type.: TM Preferred: 10/6/2017 Caller phone...: 727-277-3639


Serial No.: K860856086
Model no : 30.ODL6-15R/245100
Kilowatts : 30 Volt: 208 Phase: 3


REPLACE BATTERY DURING GENERATOR MAINTENANCE

Qty	Part number	Description	Tech note
1.00	24-700	Battery, Vehicle, 24,700-999CCA, Top Post	Replace Batt of PPD

TERMS & CONDITIONS: I have read and agree to the TAW terms and conditions available at www.tawinc.com. Agreed by: 

WORK AUTHORIZATION: This labor and material is ordered by me for which I have the authority to order. Authorized by: 

WORK ACCEPTANCE: Having examined the work done, both work and materials are satisfactory. Accepted by: 

Tech signature: 
Date.....: 10/6/17
Hours.....: 6SS.5

Date: ___/___/___ Date: ___/___/___ Date: ___/___/___



TAW Power Systems, Inc.

9/27 Weds

6312 78TH STREET
RIVERVIEW, FL 3357
Tel: 800-456-944
Fax: (813) 217-846

TAW Service Order

BILL TO: 201551 **Net 30 days**
NORTHBROOK HEALTH & REHAB CENTER
575 LAMAR AVE
BROOKSVILLE, FL 34601

SHIP TO: 201551
NORTHBROOK HEALTH & REHAB
575 LAMAR AVE
BROOKSVILLE, FL 34601

(352)799-2226

Lat.: 28.550488
Lon.: -82.393650

LOADBANK PAPERWORK

Service ID : SO26443395 Major ... No *V. Crawford*
Agreement : SA26325101 Tech ... ~~Assigned~~ Tech
Service type : LB Preferred: 9/1/2017

Serial No : K860856086
Model no : 30.ODL6-15R/245100
Kilowatts : 30 Volt: 208 Phase: 3

Customer PO : 00430100
Caller name : DEAN
Caller phone : 727-277-3639

PERFORM 4 HOUR LOAD BANK

Qty Part number Description

Tech note

head test comp in Nels

TERMS & CONDITIONS: I have read and agree to the TAW terms and conditions available at www.tawinc.com. Agreed by: *[Signature]*

WORK AUTHORIZATION: This labor and material is ordered by me for which I have the authority to order. Authorized by: *[Signature]*

WORK ACCEPTANCE: Having examined the work done, both work and materials are satisfactory. Accepted by: *[Signature]*

Tech signature: *[Signature]*
Date: 10/6/17

Hours: 655.5

Date: ___/___/___

Date: ___/___/___

Date: ___/___/___



TAW POWER SYSTEMS

SERVICE ORDER NO.

JOB NAME: northbrook health & rehab

DATE: oct 6 17

GEN MOD: 30.ODL6-15R


GEN S/N: k860856086

ENG MOD:

ENG S/N:

TIME	VOLTAGE			CURRENT			KW LOAD	Hz	WATER TEMP	OUT/S TEMP	ROOM TEMP	OIL PRESS	FUEL PRESS
	A-B	B-C	A-C	A	B	C							
830	208	208	208	61	61	61	80%	60	170			75	
15	208	208	208	61	61	61	80%	60	170			70	
30	208	208	208	61	61	61	80%	60	170			55	
45	208	208	208	61	61	61	80%	60	170			55	
930	208	208	208	61	61	61	80%	60	170			55	
15	208	208	208	61	61	61	80%	60	170			55	
30	208	208	208	61	61	61	80%	60	170			55	
45	208	208	208	61	61	61	80%	60	170			55	
1030	208	208	208	61	61	61	80%	60	170			55	
15	208	208	208	61	61	61	80%	60	170			55	
30	208	208	208	61	61	61	80%	60	170			55	
45	208	208	208	61	61	61	80%	60	170			55	
1130	208	208	208	61	61	61	80%	60	170			55	
15	208	208	208	61	61	61	80%	60	170			55	
30	208	208	208	61	61	61	80%	60	170			55	
45	208	208	208	61	61	61	80%	60	170			55	
1230	208	208	208	61	61	61	80%	60	170			55	

REMARKS:

CUSTOMER SIGNATURE: 

SERVICEMAN SIGNATURE: 

DATE: _____

DATE: 10-6-17



TAW Power Systems, Inc.

Weds 9/27



6312 78TH STREE
RIVERVIEW, FL 3357
Tel: 800-456-944
Fax: (813) 217-846

TAW Service Order

BILL TO: 201551 **Net 30 days**
NORTHBROOK HEALTH & REHAB CENTER
575 LAMAR AVE
BROOKSVILLE, FL 34601

SHIP TO: 201551
NORTHBROOK HEALTH & REHAB
575 LAMAR AVE
BROOKSVILLE, FL 34601

(352)799-2226

Lat.: 28.550488
Lon.: -82.393650

MINOR

Service ID :: SO26443397 Major ...: No *V. Crawford*
Agreement :: SA26325101 Tech ...: Unassigned Tech
Service type : PMSA Preferred: 9/1/2017
Customer PO : 00430100
Caller name : DEAN
Caller phone : 727-277-3639

Serial No : K860856086
Model no : 30.ODL6-15R/245100
Kilowatts : 30 Volt: 208 Phase: 3

PERFORM SEMI-ANNUAL PM INSPECTION TO GENERATOR

Qty Part number Description

Tech note

Minor PM comp w/in A/c

Tech signature: *[Signature]*

Date: 10/6/17

Hours: 655.5

TERMS & CONDITIONS: I have read and agree to the TAW terms and conditions available at www.tawinc.com. Agreed by: *[Signature]*

WORK AUTHORIZATION: This labor and material is ordered by me for which I have the authority to order. Authorized by: *[Signature]*

WORK ACCEPTANCE: Having examined the work done, both work and materials are satisfactory. Accepted by: *[Signature]*

Date: ___/___/___

Date: ___/___/___

Date: ___/___/___



TAW POWER SYSTEMS INC-TAMPA

6312 78th Street Riverview FL 33578

866-860-6267

GENERATOR MAINTENANCE INSPECTION REPORT

DATE 10-6-17

Service Order: _____

CUSTOMER: NORTHBROOK HEALTH & REHAB Address: 575 LAMAR AVE

PRE-CHECK VISUAL INSPECTION City: BROOKSVILLE

GENERATOR MAKE: ONAN Spec Number: 245100 Serial nm: K860856086

Generator KW: 30 Engine Serial: K853153632

ATS MAKE: ONAN Model: OTECA-5799801 Serial: C070031190 Voltage: 208

Diesel Yes Nat Gas 0 Propane 0

HRS Before Run 1303 651.2

HRS After Run 655-5

- No 1. Lube oil and filter(s) changed.
- Yes 1.a. Lube oil level verified full
- No 2. Oil samples taken for spectro-analysis.
- No 3. Fuel filter(s) changed
- No 4. Water filter/conditioner changed.
- Yes 5. Inspect and clean air filters(s).
- Yes 6. Air intakes and outlets checked.
- Yes 7. Coolant level checked. Full Yes Added Qty _____
- Yes 8. Radiator mounting brackets and braces checked.
- Yes 9. Anti-freeze checked. _____ Spectro analysis. Anti-freeze level +/- _____
- Yes 10. All engine hoses and clamps checked.
- Yes 11. Belts inspected and adjusted as required.
- Yes 12. Front and rear engine supports checked.
- Yes 13. Generator set checked for fuel, oil and coolant leaks.
- Yes 14. Battery charger operations & charge rate checked and adjusted.
- Yes 15. Battery electrolyte levels and specific gravity checked. Specific Gravity: _____ LEVEL: _____
- Yes 16. Battery load tested.
- Yes 17. Engine heater operation checked.
- No 18. Exhaust line drained.
- Yes 19. Check Electrical Connections
- Yes 20. GENERATOR RUNNING CHECKS
- Yes 21. Governor adjusted / Frequency adjusted & recorded
- Yes 22. Generator output voltage adjusted and recorded:
- Yes 23. Engine alternator charge rate checked and recorded:
- Yes 24. Oil pressure recorded:
- Yes 25. Water temperature recorded:
- Yes 26. Engine and generator gauge & indicator operations checked.
- No 27. Emergency systems with load transfer tested.
- Yes 28. Emergency system without load transfer tested.
- Yes 29. Transfer switch inspected for corrosion.
- Yes 30. Transfer switch and accessory operation checked. Exercise Program:
- No 31. Emergency shutdown functions and emergency stop tested.
- Yes 32. Paralleling equipment operation checked.
- Yes 33. Fuel Level F Tank size 0 Sample _____
- Yes 34. Generator Breaker(s) manually operated

Battery Tests Static 1303

Charger voltage _____

Voltage Drop 874

NO LOAD	LOAD
60	
208	
1330	
55	
170	

Peak Amp Inrush: _____

TDES _____

TDNE _____


TDEN _____


TDEC _____

Customer Signature Required for testing ATS or Transfer Of Load!!!!

Name: _____ Print: _____

Notes: _____

Inspection Performed By:  Print Name: _____

Inspection Approved By:  Print Name: _____

3. B. 3. 4. 5. 6.

RISK ASSESSMENT PROCOTOL

DATE: 2016

This assessment is intended to identify geographic/center-specific planning issues. The results will provide insight on areas that require additional planning emphasis. Information can be obtained from state, county and local emergency management agencies; insurance information, etc.

- 1. Is the center in a hurricane evacuation zone?
Yes _____ No: X
- 2. Is the center located within a 100-year floodplain?
Yes: X No _____

Provide additional information concerning center's location within an established flood zone (per flood insurance rate map):

Ponding Area (See Map)

- 3. Is the center located near (within one-quarter mile) an active railroad track system or major highway? If "Yes," identify transportation route (e.g., Interstate 45) and provide approximate distance to each.

Railroad Line: $\frac{1}{2}$ mile "CSX" No Stops in Brooksville
Highway: Highway 50 - $\frac{1}{4}$ (one-quarter) mile

- 4. Is the center located within the 10/50-mile Emergency Planning Zone of a commercial nuclear power facility?
10 mile: Yes _____ No: X
50 mile: Yes: X No _____

- 5. Is the center located in an earthquake-prone area?
Yes _____ No: X

- 6. Is the center located in a geographic area prone to severe and/or prolonged winter storms?
Yes _____ No: X

- 7. Is the center located in a tornado-prone area?
Yes _____ No: X

11